

To, Dated: 25-07-2023

The Head, Army Public School Birpur, Dehradun.

Subject: Certificate for hydraulic test

Sir,

This is to certify that Ceasefire fire Extinguisher installed in your premise were all manufactured & tested as per norms, tested & passed hydraulic pressure test before delivery also its performance were satisfactory.

## **Following were Technical Description of Products:**

Description of Pressure Equipment: Power Fire Extinguisher

Content Type: Dry Powder Working Pressure: 15kgf/cm<sup>2</sup> Test Pressure: 35kgf/cm<sup>2</sup>

Description of Pressure Equipment: Clean Agent Fire Extinguisher

**Content Type**: Clean Agent **Working Pressure**: 10.5kgf/cm<sup>2</sup>

Test Pressure: 35kgf/cm<sup>2</sup>

Warm Regards

**Authorized Signatory** 

Ajay V -1

Ceasefire Industries Pvt. Ltd. 19, Ashok Vihar, G.M.S. Road Dehradun (U.K.) GST No. 05AABCC8940P1Z9

EXTENSIVE RANGE OF FIRE EXTINGUISHERS | SPECIAL APPLICATION FIRE EXTINGUISHERS | MICRO ENVIRONMENT FIRE SUPPRESSION | FIRE SUPPRESSION SYSTEMS | KITCHEN FIRE SUPPRESSION SYSTEMS | FIRE ALARM SYSTEMS | FIRE PROJECTS | ANNUAL MAINTENANCE CONTRACT | FIRE TRAINING | REFILLING | ACCESSORIES



To, Dated: 25-07-2023

The Head, Army Public School, Birpur, Dehradun

Subject: Performance Certificate of Ceasefire fire extinguisher

## Sir/Madam,

This is to certify that as per our fire audit survey we found that the extinguisher installed at your premises were good and its performance was satisfactory. The survey report were enclosed below with the location of the extinguishers & inspection details:

SI	Point Of Installation	Existing Extinguisher			
		Ceasefire 2kg MAP	Ceasefire 2kg Clean Agent	Ceasefire Automatic Ceiling Mounted 5kg	Status
1	Vice Principal	1			ok
2	XI C	1			ok
3	SR. COMPUTER LAB		1		ok
4	XII E	1			ok
5	XII B	1			ok
6	PHYSICS LAB	1			ok
7	CHEMISTY LAB	1			ok
8	XI-A	1			ok
9	LIBRARY	1			ok
10	SERVER ROOM			1	ok
11	EXAMINATION ROOM		1		ok
12	RECEPTION	1			ok
13	IX-A	1			ok
14	IX E	1			ok
15	TEACHER PARADISE	1			ok
16	VII-E	1			ok
17	VII-C	1			ok
18	VI-B	1			ok
19	STAFF ROOM	1			ok
20	VI-E	1			ok
21	VIII-A	1			ok
22	Jr. Computer Lab		1		ok
	Total	18	3	1	

Warm Regards



**Authorized Signatory** 

Ceasefire Industries Pvt. Ltd. 10, Ashok Vihar, G.M.S. Road Dehradun (U.K.) GST No.-05AABCC8940P1Z9